

RFQ 2018-635 Traveling Bridge

Due Date Extended to January 4, 2018, 2:00 PM

Questions with responses received as of December 18, 2017:

Can you provide a manufacturer or part number for rail with stainless wear cap? **I do not know the manufacturer for the rails and cap,**

Have any engineering specs been provided for this project?**The specs are only the intent of the project as laid out. No specific measurements, all interested parties can come by the plant and are welcome do all the measuring they need. The intent is to match the existing rails.**

What specs do rails need aligned to or leveled to?

The intent is to match the existing rails in height and width. There are no drawings that we could find from 1973 to indicate how they installed it originally.

If this is the same project our staff looked at a few months ago. Then I would like some on site discussion with someone familiar with project. **YES and you are welcome to come to the plant and look it over.**

It specifies Chalkfast, can another manufacturer be used for grout? **NO. Red Chalk Fast is what we need. There are no numbers for red. their web page only shows 3 types red, blue and grey. Red is for machinery and vibration so that is the type we require. We have had good success with the red.**