



CITY OF AZTEC

ADDENDUM # 4

ITB # 2025-861 HARTMAN PARK FIELD LIGHTING

ADDENDUM DATE: January 27, 2025

BID DUE DATE/ TIME: January 30, 2025, 3:00 PM

This addendum includes the following:

1. One Line Drawing of the Electrical Installation (Exhibit D).

Provided in the attached exhibit.

2. Answers to Questions Submitted

Q: What is the weight of each light pole?

A: MSM document lists the weight of each at 850lbs but Cooper Lighting states 800lbs. Add approximately another 400lbs for the lights, drivers, wire and mounting arms.

Q: Please confirm that per Addendum One Exhibit A "Basis of Bid" items 4 through 8 this is to be a labor only bid, all materials provided by others.

A: The City will provide the lights, mounting arms, and poles for this project. However, all other materials and labor beyond these three items, such as conduit, must be included in the bid. Additionally, mats to protect the grass should be factored into the bid to ensure preservation. The contractor will not be responsible for reseeding or restoring the grass.

For Further Information Contact:
Vanessa Tanner, Project Procurement Specialist, CPO
Phone: 505-334-7652
Fax: 505-334-7649
email: vtanner@aztecnm.gov

EXHIBIT D

