



City of Aztec  
Request for Quotation  
RFQ # 2025-854 Chain Link Fence for Dump Station  
Due: July 22, 2024

Date: July 15, 2024

Question & Answers

1. What gauge of chainlink would you like bid?

ANSWER: 9 gauge chain link

2. What size and gauge of line posts, terminal posts, and toprail would you like bid?

ANSWER: 2 3/8" line post, 2 7/8" corner post, 1 5/8" toprail. Pipe sizing needs to be 40 weight.

3. Can we substitute a cantilever gate in place of a standard roll gate with concrete and a track? A cantilever is a actually a better gate system and will actually save you money not having to pour a concrete footing for the gate track. Cantilever gates are suspended off the ground between gate rollers, so you also don't have to worry about snow and ice affecting the gate travel like you do with a gate track system.

ANSWER: Yes, a cantilever system is acceptable.