



NOTE:

1. #4 REBAR 12" O.C. IN BOTH DIRECTIONS
2. SCH. 40 STEEL
3. ALL DIMENSIONS ARE SUBJECT TO CHANGE DEPENDING ON FLOW REQUIREMENTS AND SCOUR DEPTH.
4. REBAR SHALL BE PLACED 3" FROM UP STREAM FACE IN WALL AND 3" FROM BOTTOM IN FOOTER.
4. USE 4000 P.S.I. CONCRETE

CONSTRUCTION
STANDARDS

EROSION CONTROL WALL

STANDARD No. D-611 SHEET 1 OF 1

CITY OF
AZTEC
PUBLIC WORKS
DEPARTMENT