


NOTE:

AS DETERMINED BY A.S.T.M. D-1557
 A.A.S.H.T.O. DEG T-147-FIELD TEST
 MOISTURE CONTENT OF ALL COMPACTION
 SUBGRADE MATERIAL IN PLACE SHALL
 BE NO GREATER THAN OPTIMUM NOR
 ANY LESS THAN OPTIMUM MINUS 5%

CUT AND BACKFILL IN ROCK
 FOR MANHOLES



**TRENCH CUTS
 (MANHOLES)
 TRENCH WIDTHS**

CONSTRUCTION STANDARDS

STANDARD NO. SS-11

SHEET 1 OF 1

APP'D R. Salcido
 DATE Oct. 11, 2023