


**NOTE:**

1. TOP 6" OF BASE COURSE ON PAVED RESIDENTIAL STREETS & TOP 12" OF PAVED ARTERIAL STREETS TO BE COMPACTED TO 95% MODIFIED PROCTOR.
2. UNPAVED STREETS & OTHER AREAS TO BE 95% MODIFIED PROCTOR.
3. WITHIN CITY ROW PIPE BEDDING & TRENCH BACK FILL SHALL BE BASE COURSE.
4. TRENCH DETAILS FOLLOW OSHA 1926 SUBPART P APP B - EXCAVATION: SLOPING AND BENCHING.

PIPE DIA.	TRENCH WIDTH	PIPE DIA.	TRENCH WIDTH
8"	2'-6"	30"	6'-8"
10"	2'-8"	36"	7'-0"
12"	3'-0"	42"	8'-0"
15"	3'-0"	48"	8'-6"
18"	4'-6"	54"	10'-6"
21"	4'-6"	66"	13'-0"
24"	5'-6"	72"	14'-0"



**TRENCH DETAILS  
72" O.D. PIPE OR LESS**

**CONSTRUCTION STANDARDS**

**STANDARD NO. SS-12**

**SHEET 1 OF 4**

APP'D R. Salcido  
DATE Oct. 11, 2023