



NOTE

1. ALL TAP SADDLES OVER 4" SHALL BE TWO PIECE STAINLESS STEEL CAPABLE OF FITTING A/C, DI OR PVC PIPE.

 <p>City of Aztec Public Works Department</p>	<p>WATER LINE CONNECTION DETAILS</p>	<p>STANDARD NO. W-1</p>
	<p>CONSTRUCTION STANDARDS</p>	<p>SHEET 2 OF 2 </p> <p>APP'D <u>R. Salcido</u> DATE <u>Oct. 11, 2023</u></p>