


* CONTRACTOR SHALL INSTALL DOUBLE CHECK VALVE/BACKFLOW PREVENTOR AND VAULT PRIOR TO METER INSTALLATION.

PREFERRED INSTALLATION BY OWNER

4. CONTRACTOR SHALL INSTALL PIPE THROUGH THE METER PIT. THE CITY WILL CUT THE PIPE AND INSTALL THE METER AT A LATER DATE.
- * 5. SHOULD THE CITY DEEM THE USE OF THE PROPERTY AS HIGH HAZARDOUS, THEN AN RP BACKFLOW IN LIEU OF THE DOUBLE CHECK VALVE WILL BE REQUIRED.
6. TAMPERING AND ACCESS OF METER PIT IS PROHIBIT FOR ACCESS INTO METER PIT. CONTACT CITY'S PUBLIC WORKS DEPT.
7. THE CITY SHALL INSTALL WATER METER & STRAINER UPON INSPECTION AND APPROVAL. OF THE METER PIT & BACKFLOW PREVENTOR ASSEMBLY BY THE CONTRACTOR.

- NOTE:
1. FOR COMMERCIAL PROPERTIES WITH ZERO LOT LINE PLACE METER ONE FOOT BEHIND CURB.
 2. ALL METERS SHALL BE INSTALLED BEHIND SIDEWALK & OUTSIDE OF PROPOSED DRIVEWAY.
 - * 3. OWNER IS RESPONSIBLE TO INSTALL DOUBLE CHECK VALVE ASSEMBLY AND VALVE BOX PRIOR TO WATER METER INSTALLATION.



LARGE WATER METER VAULT DETAIL 3" METER

CONSTRUCTION STANDARDS

STANDARD NO. W-14

SHEET 1 OF 1

APP'D R. Salcido
DATE Oct. 11, 2023