



NOTES:

1. SEE STD. W-4 SHEET 1 OF 2 FOR THE PRV MATRIX TABLE FOR BLOW OFF AND VENT PIPE SIZING.
2. BLOW OFF PIPE AND VENT LOCATION TYPICAL 1ft BEHIND SIDEWALK
3. MINIMUM 10ft HORIZONTAL SEPARATION FROM THE VAULT FOR BIDDING PURPOSES.
4. LOCATION OF THE BLOW OFF AND VENT PIPES SHALL BE DETERMINED IN THE FIELD BY THE CITY.



**BLOW-OFF AND
VENT PIPE DETAIL**

CONSTRUCTION STANDARDS

STANDARD NO. W-4

SHEET 2 OF 2

APP'D R. Salcido
DATE Oct. 11, 2023