


NOTE:

1. MINIMUM DIRECT DISTANCE FIRE HYDRANT TO GATE VALVE SHALL BE 8'-0".
 2. ALL JOINTS SHALL BE MEGA-LUGS.
 3. LUBRICATE HYDRANT NOZZLE THREADS WITH NON-TOXIC GREASE.
 4. NON FLANGED FIRE HYDRANT JOINTS REQUIRE MEG-A-LUG OR APPROVED EQUAL.
 5. THE TOP SIDE OF THE 48" CONCRETE PAD SHALL BE LOCATED FLUSH AND LEVEL WITH THE BACKSIDE SIDEWALK ELEVATION.
 - IF NO SIDEWALK AREA; FLUSH WITH THE BACK OF SIDEWALK (FUTURE) ELEVATION.
 - IF NO CURB & GUTTER; FLUSH WITH THE FINAL ROAD ELEVATION.
 - IF NO ROAD FRONTAGE; FLUSH WITH THE FINAL GROUND ELEVATION.
- ANY GROUND SLOPE REMEDIATION SURROUNDING THE "CLEAR-AREA" SHALL BE COMPLETED BY THE CONTRACTOR, PRE-AUTHORIZED BY THE CITY.



**FIRE HYDRANT
OFFSET ALTERNATE**

CONSTRUCTION STANDARDS

STANDARD NO. W-6

SHEET 4 OF 7

APP'D R. Salcido
DATE Oct. 11, 2023