

MEG-A-LUGS ARE REQUIRED UNLESS APPROVED BY WATER & WASTEWATER ADMINISTRATOR
TABLE OF BEARING AREAS IN SQ. FT FOR CONCRETE
THRUST BLOCKING

FOR 150 P.S.I. INTERNAL STATIC PRESSURE AND 2000 LBS. PER SQ. FT SOIL BEARING CAPACITY.

PIPE SIZE	BENDS				TEES	PLUGS
	90°	45°	22 1/2°	11 1/4°		
4	1.50	0.75	0.50	0.0	1.00	1.00
6	3.00	1.75	1.00	0.0	2.25	2.25
8	5.50	3.00	1.50	1.00	3.75	3.75
10	8.50	4.50	2.50	1.50	6.00	6.00
12	12.00	6.50	3.50	1.75	8.50	8.50
14	16.50	9.00	4.50	2.25	11.50	11.50
16	21.50	11.50	6.00	3.00	15.00	15.00
18	27.00	14.75	7.50	3.75	19.00	19.00
20	33.50	18.00	9.25	4.75	23.50	23.50
24	48.00	26.00	13.25	6.75	34.00	34.00
30	75.25	40.75	20.75	10.50	53.00	53.00
36	108.25	58.50	30.00	15.00	76.50	76.50



AREAS GIVEN IN TABLE ARE BASED UPON AN INTERNAL STATIC PRESSURE OF 150 P.S.I. AND A SOIL BEARING CAPACITY OF 2000 LBS. PER SQ. FT. BEARING AREAS FOR ANY PRESSURE AND SOIL BEARING CAPACITY MAY BE OBTAINED BY MULTIPLYING THE TABULATED VALUES BY A CORRECTION FACTOR "F".

$$F = \frac{\text{ACTUAL SPECIFIED TEST PRESSURE IN HUNDREDS OF LBS.}}{\text{ACTUAL SOIL BEARING CAPACITY IN THOUSANDS OF LBS.}}$$

EXAMPLE: TO FIND BEARING AREA FOR 8" - 90° BEND WITH A STATIC INTERNAL PRESSURE OF 100 P.S.I. AND WITH A SOIL BEARING CAPACITY OF 3000 LBS. PER SQ. FT.

$$F = \frac{100}{3000} = .33 \text{ TABULATED VALUE} = 550 \text{ SQ. FT.}$$

$$0.33 \times 550 = 1.82 \text{ SAY } 2 \text{ SQ. FT. OR } 2 \text{ FT. LONG BY } 1 \text{ FT. HIGH}$$

 City of Aztec Public Works Department	THRUST BLOCKS	STANDARD NO. W-8
	CONSTRUCTION STANDARDS	SHEET 2 OF 2  APP'D <u>R. Salcido</u> DATE <u>Oct. 11, 2023</u>